

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. C.M.O./21

Dated: 14-09.2026

It is certified that an inspection team headed by Dr. Abhishek Yadav

(Name of Officers with designation) from Dy CMO PHED

inspected the ST MERRY SCHOOL, RAIBHA AGRA-UP.

(Name & Address of the school) on 11-09.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no Chemical Water Analysis Test Report , Bharat Testing Laboratory Privet Limeted. dated 11-09-2026 of Jalkal Vibhag Agra (PHED Lab) ✓ certified that the ST MERRY SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31<sup>st</sup> March, 2027

Signature with Seal:  उप मुख्य चिकित्सा अधिकारी

Name : Dr. Abhishek Yadav

Designation : Dy. CMO

Name & Address of the Office / Department:

Office Chief Medical officer near Central Jail road, Agra.

To

ST MERRY SCHOOL,  
RAIBHA AGRA-UP  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



# BHARAT TESTING LABORATORY PRIVATE LIMITED

Address.: C-63, Sector-88, Phase-II, Noida, Gautam Buddh Nagar (U.P.) - 201305

(An ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)

Mob.: +91 8368298308, +91 9643040990, +91 9911003929, +91 9811003929



TC-17670

Doc. No. -BTL/7.8-01  
BTL/W-070926-17, Page No.-1 of 2

## TEST REPORT

### Water Sample Analysis

Report Code-BTL/W-070926-17

Date : 11/09/2026

Issued To: St. Merry School  
Raibha, Agra

### SAMPLING & ANALYSIS DATA

|                               |                                                          |
|-------------------------------|----------------------------------------------------------|
| Sample Description            | Drinking Water                                           |
| Sample Drawn On               | 07/09/2026                                               |
| Sample Drawn By               | DEEPAK BTL LAB Representative                            |
| Sampling Plan & Procedure     | IS:17614 (Part):2021                                     |
| Sample Quantity               | 2.0 Liter in Pet Bottle & 500 ml Glass Sterilized Bottle |
| Weather Condition             | Clear                                                    |
| Sample Received On            | 07/09/2026                                               |
| Analysis Duration             | 08/09/2026 To 11/09/2026                                 |
| Test Specification To Be Used | IS:10500:2012                                            |

### ANALYSIS TEST RESULTS

| S. No. | Test Parameter                                | TEST Method         | Results   | Requirement (Acceptable Limit) | Permissible Limit in absence of alternate source |
|--------|-----------------------------------------------|---------------------|-----------|--------------------------------|--------------------------------------------------|
| 1      | pH Value @ 25°C                               | IS:3025(Part-11)    | 7.02      | 6.5 – 8.5                      | -                                                |
| 2      | Colour (Hazen)                                | IS:3025(Part-04)    | <1.0      | 5.0                            | 15                                               |
| 3      | Odour                                         | IS:3025(Part-05)    | Agreeable | Agreeable                      | Agreeable                                        |
| 4      | Taste                                         | IS:3025(Part-7 & 8) | Agreeable | Agreeable                      | Agreeable                                        |
| 5      | Turbidity (NTU)                               | IS:3025(Part-10)    | <1.0      | 1.0                            | 5.0                                              |
| 6      | Total Hardness (as CaCO <sub>3</sub> ) (mg/l) | IS:3025(Part-21)    | 36.0      | 200                            | 600                                              |
| 7      | Chloride(as Cl) (mg/l)                        | IS:3025(Part-32)    | 35.5      | 250                            | 1000                                             |
| 8      | Calcium (as Ca) (mg/l)                        | IS:3025(Part-40)    | 10.80     | 75                             | 200                                              |
| 9      | Total Iron (as Fe) (mg/l)                     | IS:3025(Part-53)    | <0.05     | 1.0                            | -                                                |
| 10     | Nitrate (as NO <sub>3</sub> ) (mg/l)          | IS:3025(Part-34)    | <1.0      | 45                             | No Relaxation                                    |
| 11     | Total Dissolved Solid (TDS) (mg/l)            | IS:3025(Part-16)    | 108       | 500                            | 2000                                             |
| 12     | Alkalinity (as CaCO <sub>3</sub> ) (mg/l)     | IS:3025(Part-23)    | 36.0      | 200                            | 600                                              |
| 13     | Fluoride (as F) (mg/l)                        | IS:3025(Part-60)    | <0.1      | 1.0                            | 1.5                                              |
| 14     | Magnesium (as Mg) (mg/l)                      | IS:3025(Part-46)    | 2.19      | 30                             | 100                                              |

#### NOTE:

1. The Results given above are related to the tested sample, as received & mentioned parameters. The Customer Asked for the above tests only.
2. Responsibility of the Laboratory is Limited to the Invoiced Amount only.
3. This test report will not be generated again, either wholly or in part, without Prior Written Permission of the Laboratory.
4. This test report will not be used for any Publicity/Legal Purpose.
5. The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.
6. This is Computer Generated Report does not Require Physical Delivery

Reviewed by

*[Signature]*

Authorized Signatory



भारत है तो भरोसा है।



# BHARAT TESTING LABORATORY PRIVATE LIMITED

Address.: C-63, Sector-88, Phase-II, Noida, Gautam Buddh Nagar (U.P.) - 201305

(An ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)

Mob.: +91 8368298308, +91 9643040990, +91 9911003929, +91 9811003929

Doc. No. -BTL/7.8-01

BTL/W-070926-17 Page No.-2 of 2

## Microbiological Analysis

| S. No. | Test Parameter    | Test Method   | Results | Required as per IS-10500:2012 |
|--------|-------------------|---------------|---------|-------------------------------|
| 1      | Escherichia coli  | IS-15185:2016 | Absent  | Absent/100ml                  |
| 2      | Coliform Bacteria | IS-15185:2016 | Absent  | Absent/100ml                  |

**Remarks:** Based on above tested parameter, Water sample meets as per IS-10500:2012 in specification.  
Hence water is fit for Drinking purpose

## NOTE:

1. The Results given above are related to the tested sample, as received & mentioned parameters. The Customer Asked for the above tests only.
2. Responsibility of the Laboratory is Limited to the Invoiced Amount only.
3. This test report will not be generated again, either wholly or in part, without Prior Written Permission of the Laboratory.
4. This test report will not be used for any Publicity/legal Purpose.
5. The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.
6. This is Computer Generated Report does not Require Physical Delivery

(Microbiologist)

\*\*\*End of Report\*\*\*

Authorized Signatory



भारत है तो भरोसा है।